Energy Audit for the

academic year 2020-21

and 2021-2022 are

CONDUCTED BY

"DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/s. DESIGN POWER"



ENGINEERING CONSULTANT, ENERGY AUDITOR & PROJECTS

Office:

Unit No- 121, Lodha Supremus- II, Road No- 22, Wagle Estate, Thane West, Maharashtra 400 604.

Registered Office:

301, Maitri CHS, Ganesh Nagar Road, Nava Pada, Vishnunagar, Dombivli (W) 421 202

Contact Numbers:

9702703432 9967775157

Email Id:- <u>designpowerconsultant@gmail.com</u> <u>designpower777@gmail.com</u> <u>designpower@consultant.com</u>

Web site: www.designpower.in

(Mission Statement---Go Green....Don't Waste (Paper, Electricity, Petrol, Water, Food, Time, and Money.... Say YES to Energy Efficiency...)

A REPORT ON

MEP AUDIT OF

Karnataka Sangha's Manjunatha College of Commerce & Jr.College of Commerce

Thakurli East, Thane 421 201

AUDIT CONDUCTED BY;



DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/s. DESIGN POWER ISSUE-P0 Dated 24th March 2022

MONTH - March 2022

This Energy Audit is for the year 2020-21



For M/S. DESIGN POWER

DESIGN POWER

Proprietor Authorized Signatory DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/s. DESIGN POWER

(ENGINEERING CONSULTANT, ENERGY AUDITOR & PROJECTS)

UNIT NO-121, LODHA SUPREMUS – II, ROAD NO- 22, WAGLE ESTATE, THANE (W). 400604. PH: +91 9702703432. E MAIL: designpower777@gmail.com, Web: www.designpower.in.



| Sr. | | OBSERVATION & |
|-----|--|---|
| No. | | RECOMMENDATION |
| | | Blank plate Missing. Restore the same. Provide proper earthing Pits. |
| | | |
| | | |
| | | For M/S. DESIGN POWER Proprietor Authorized Signatory DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/S. DESIGN POWER |

MEP AUDIT REPORT - MANJUNATH COLLEGE OF COMMERCE & JR. COLLEGE OF COMMERCE













| KR | Loose cables, very dirty area, no proper electrical connections. Replace with proper switch boards having MCB and industrial sockets. |
|-----------|---|
| | |
| | |
| | Do the proper dressing, remove unwanted material. Condition is worst. Do proper connection. Provide CO2 Extinguisher in Electrical Rooms. For M/S. DESIGN POWER Authorized Signatory DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/S. DESIGN POWER |



| | Open wire leads and very old wiring, needs to be replaced with FRLS wiring. |
|---|---|
| जनाथ वाणिज्य स राष्ट्रीय चेवा "NOT ME F | Remove all loose wires. Do proper dressing. Avoid Papers in Electrical room. |
| | Restore DB cover, Use Blank plates, Provide RCCB, Cable sealed are open, |
| | Use proper extension for Computers, no loose wires. Remove papers from Electrical room. |
| | Use proper extension for Computers, no loose wires. For M/S. DESIGN POWER Proprietor Authorized Signatory DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/S. DESIGN POWER |



GENERAL

Entire Old wiring is in worst condition. This will lead to electric shock hazards and electric fire hazard. It is required to rewired properly with FRLS wires and cables and proper distribution with protective devices.

For M/S. DESIGN POWER

Abance Proprietor Authorized Signatory DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/s. DESIGN POWER





A REPORT ON

ENERGY AUDIT OF

Karnataka Sangha's Manjunatha College of Commerce & Jr.College of Commerce

Thakurli East, Thane 421 201

AUDIT CONDUCTED BY;





DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/s. DESIGN POWER

ISSUE-R1 Dated 30th March 2022

MONTH - March 2022

This energy Audit is for the year 2021-2022



DESIGN POWER



(ENGINEERING CONSULTANT, ENERGY AUDITOR & PROJECT Sprietor

UNIT NO-121, LODHA SUPREMUS – II, ROAD NO- 22, WAGLE ESTATE, THANE (W). 400604. PH: +91 9702703432. E MAIL: designpower777@gmail.com, Web: www.designpower.in.

1. ACKNOWLEDGEMENT

We are sincerely grateful to the **Principal Sir**, for entrusting the work of Energy audit and conservation to us and valuable inputs given for completing the audit, site inspection and report preparation. We express our sincere thanks to Mrs. Nisha Deodhar for extending utmost cooperation and help to make study successful.

2. Areas of Investigation:

- 2.1 Have done the survey of the entire college building and campus.
- 3. Energy Audit Team:

M/s DESIGN POWER – Certified Energy Auditor – Mumbai conducted the energy audit. The audit team considered of certified energy auditors from BEE:

- 1. Mr. Deepak K Kanchar
- 2. Mr. Parshuram Nade
- 3. Prajakta Sawant
- 4. <u>Energy Use and Areas:</u> Refer The Annexure I.
- 5. Conclusion:

Refer annexure -II. Energy saving can be obtained as per below

- a. Priority -I : Average saving 4.7 %
- b. Priority -II: Average Saving 18.5 %
- c. Priority -III : Average Saving 90 %
- 6. Enclosure:
 - a. <u>Annexure I</u>
 - b. <u>Annexure -II</u>

For M/S. DESIGN POWER

Asamen

Proprietor Authorized Signatory DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/s. DESIGN POWER



Principal Manjunatha College of Commerce Kanchangaon, Khambalpada, Thakurii (E) - 421 201.



Manjunath College of Commerce & Jr. College of Commerce, Thakurli

| | | | | | | | Date 30.03.2022 | | |
|----------|--|---|-------|------------|---------|------------|-----------------|------------|------------|
| | ANNEXURE -I | | | | | | | Rev RO | |
| DES | IGN POWER | F | NERGY | , | | | | | |
| | Smart by Design | | | | | | | | |
| | | (| CONSU | MPTION | I | | | | |
| Sr No. | Equipment | Qty | Kw | Total | Running | Consumtion | Total | Percentage | Percentage |
| | | | | Kw | time | Kw/Day | Consumption | Energy Use | Connected |
| | | | | | Hrs | | Kw /Month | | Load Kw |
| 1 | Air Conditioners | | | | - | | , | | |
| | Solit AC 2.0 TR | 0 | 2.25 | 0 | 0 | 0 | 0 | | |
| u h | Split AC 1.0 TP | 0 | 6 | 0 | 0 | 0 | 0 | | |
| U | | 10 | 2.25 | 10 F | 0 | 162 | 4050 | - | |
| C | | 18 | 2.25 | 40.5 | 4 | 102 | 4050 | 22.07 | 40.52 |
| | Sub lotal | | | 40.5 | | | 4050 | 33.07 | 40.53 |
| | | | | | | | | | |
| 2 | Computers | | | | | | | | |
| a | PC | 69 | 0.15 | 10.35 | 4 | 41.4 | 1035 | | |
| b | Printers | 16 | 0.2 | 3.2 | 2 | 6.4 | 160 | | |
| ~ | SCANNER / Lamination | | | | | | | | |
| | Machine | 6 | 0.15 | 0.9 | 2 | 1.8 | 45 | | |
| | Sub Total | | | 14.45 | | | 1240 | 10.12 | 14.46 |
| | | | | | | | | | |
| 3 | XEROX MACHINE | 1 | 0.5 | 0.5 | 1 | 0.5 | 3 | 0.02 | 0.50 |
| | | | | | | | | | |
| 4 | PROJECTOR | 9 | 0.8 | 7.2 | 4 | 28.8 | 172.8 | 2.94 | 1.00 |
| | | | | | | | | | |
| 5 | Refrigerators | | | | | | | | |
| а | 242 Ltrs | 2 | 0.5 | 1 | 12 | 12 | 360 | 2.94 | 1.00 |
| | | | | | | | | | |
| 6 | BIOMETRIC MACHINE | 1 | 0.15 | 0.15 | 4 | 0.6 | 18 | 0.15 | 0.15 |
| - | | | | | | | _ | | |
| 7 | WIELROUTERS /WEB | | | | | | 1 | | |
| , | | 25 | 0.05 | 1 25 | 18 | 22.5 | 675 | 5 51 | 1 25 |
| | | 25 | 0.05 | 1.25 | 10 | 22.5 | 0/5 | 5.51 | 1.25 |
| 0 | MIVED 9. | | | | | | | | |
| 0 | Mircowaya Oyan | 2 | 15 | 2 | 2 | 6 | 150 | | |
| a | Mircowave Oven | 2 | 1.5 | 2 | 2 | 0 | 100 | 1 | |
| | | Z | 1 | 2 | 2 | 4 | 100 | 2.04 | F 00 |
| | Sub lotai | | | 5 | | | 250 | 2.04 | 5.00 |
| 0 | Mater Damas | | | | | | | | |
| 9 | water Pumps | | | | | | 400 | | |
| a | 1 HP Water Pump | 2 | 1 | 2 | 2 | 4 | 100 | - | |
| b | | | | | | | | | |
| | Sub Total | | | 2.0 | | | 100 | 0.82 | 2.00 |
| - | | | | | | | | | |
| 10 | FANS | | | | | | | | |
| а | Table Fans | 3 | 0.1 | 0.3 | 5 | 1.5 | 37.5 | | |
| b | Ceilling Fans | 170 | 0.1 | COLL | GE 5 | 85 | 2125 | | |
| | Sub Total | | | ET-3A | URLIE | | 2162.5 | 17.66 | 17.31 |
| | | | | AND LET | ISTI MA | | | | |
| 11 | Aquaguard (BIG-2 | 4 | 0.15 | Sil de las | | 3 | | | |
| | / SMALL -2) | | | 0.6 | × | | 75 | 0.61 | 0.60 |
| | , , | 1 | | 0.0 | | 1 | | | |
| 12 | Lighting | 1 | | | | 1 | 1 | 1 | 1 |
| | Tube Light | 248 | 0.04 | 9 92 | 12 | 119 04 | 2976 | | |
| | I ED Light | 240 | 0.04 | 056 | 12 | 6 70 | 160 | | |
| | | 20 | 0.02 | 10.00 | 12 | 0.72 | 2144 | 25.67 | 10.40 |
| | | + | | 10.40 | | | 5144 | 25.0/ | 10.49 |
| | τοται | | | 00.0 | | | 122/17 2 | 101 EE | |
| | Total Consumption VIVIL Der Menth Considering Diversity 55 % | | | | | 6726.02 | 101.55 | | |
| | Total Consumption KWH | Consumption KWH, Per Wonth Considering Diversity 55 % 67: | | | | 0/30.02 | | | |

ila, X Principal Manjunatha College of Commerce Kanchangaon, Khambalpada, Thakurii (E) - 421 201.

For M/S. DESIGN POWER

Asamen Proprietor Authorized Signatory DEEPAK K. KANCHAR (EA-9077) CERTIFIED ENERGY AUDITORS M/s. DESIGN POWER



Manjunath College of Commerce & Jr. College of Commerce, Thakurli ANNEXURE-II ENERGY SAVING OPPORTUNITIES

| | | | | | | | | Date 30.03.2022 Rev R0 |
|-----------|---------------------------------------|---------------------------------|---|-------------------------|---|-------------------------|---|---------------------------|
| Sr No. | Equipme nt | Consum ption Kw /Month | Priority I | Savi ng Kw h/M | Priority II | Sav ing Kw h/M | Prioirty IiI | Saving Kwh/M |
| 1 | Air Conditioner | | | | | | | |
| | Split AC s total 27 TR | 2025 | Maintenance , Filter cleaning , Greasing and Oiling , and Setting Room Temperature 26 deg This leads to energy saving 5 % | 101.25 | System is very old and inefficent. Replace it by energy efficent Inveter AC syetm. Average saving can be 20% | 405 | System is very old and inefficient. Replace it by energy efficient VRF system. System TR with diversity will be 22 TR . Part load efficiency is very good up to 0.8 Kw per TR. Average saving can be 30% | 607.5 |
| | | | | | | | Connected Load 40.5 KW will get reduced to 33 Kw. | |
| 2 | Refrigerators | 360 | | | | | Old refrigerator to be replaced by Inverter type Refrigerator saving 30% | 252 |
| 3 | Fans | 1081 | Manual Switch off whenever not required. Regular Maintenance can save at least 5% | 54.05 | Occupancy Sensor control of Fans can save 20% | 216.2 | | |
| 4 | Water Pumps | 100 | Need to do proper maintenece . Complete overhauling. Regular maintenance , Changing Faulty Bearing, Claeaing Strainer etc. saving 5% energy. | 5 | THAKURLI HAKURLI (HAK | | Principal Manjunatha College of Comm Kanchangaon, Khambalp Thakurii (E) • 421 201 | |
| 5 | Lighting | 3144 | Manual control of lighting can save 5% | 157.2 | Occupancy Sensor control of lighting can save 20% | 628.8 | Use LED Ligthing Saving 70% | 2083.2 |
| | | | | | for | M/S. (| DESIGN POWER | |
| | Total | | | 317.5 | | 1250 | Average saving 43 % | 2942.7 |
| | TOTAL CONSUMPTION PER MONTH KWH | 6736.02 | | | | | Use of Solar roof top Power Plant of Capacity 50 Kw. Approx project cost Rs. 33,60,000/- and Payback will be 40 month i.e. 3.3 Yrs. | 6000 |